

## EC Declaration of Conformity

The company **tiko Energy Solutions AG**

**declares, that the following product of the TIKO 3Musk family**

Product	Identification
Meter-Box (Aramis)	P.N. CMM-01.1012-01-P1

**in the form as delivered conform to the provisions of the following European directives:**

**2011/65/EU**

*on the restriction of the use of certain hazardous substances in electrical and electronic equipment*

**2014/35/EU**

*on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits*

**2014/30/EU**

*on the harmonisation of the laws of the Member States relating to electromagnetic compatibility*

**The conformity with the essential requirements of the directive is assured through the application of the following standards:**

Description	Sub called directive	Certificate
Safety	2014/35/EU	EN 61010-1:2010 (Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements)
EMC	2014/30/EU	EN 62052-11:2003 (Electricity metering equipment (AC) - General requirements, tests and test conditions - Part 11: Metering equipment) EN 55032:2015 (Electromagnetic compatibility of multimedia equipment - Emission Requirements) EN 55024:2010 (Information technology equipment - Immunity characteristics - Limits and methods of measurement) EN 61000-6-1:2007 (Immunity for residential, commercial and light-industrial environments) EN 61000-6-3:2007 / AC2012 (Generic standards - Emission standard for residential, commercial and light-industrial environments)

**2004/22/EC**

*Directive on measuring instruments*

**The conformity with the essential requirements of the directive is partial and it is assured through the application of the following standards:**

<b>Description</b>	<b>Certificate</b>	
Metrology	EN50470-1:2006, EN50470-3:2006	(active energy class C)
	TR50579	(Electricity metering equipment (a.c.) - severity levels, immunity requirements and test methods for conducted disturbances in the frequency range 2 kHz - 150 kHz)

The products are marked with the CE sign.

Zürich, 2020-08-13



Chief Executive Officer

Frederic Gastaldo



Chief Quality Officer

Benjamin Sawicki

This declaration certifies the conformity to the specified directive but contains no assurance of properties. The safety documentation accompanying the product shall be considered in detail.